

2011-03-24 Thursday Morning Notes

Thursday, March 24, 2011

7:42 AM

- Studies
 - Antihydrogen studies
 - Had trouble opening A:BV862
 - Ion pumps for permit are all on, but sector valve page shows no permit.
 - Open valve request stays infinite.
 - Controls will help us with valve, hopefully we can continue before we access.
 - Access later today, Friday or Monday depending on results of above studies.
 - Only a few jobs in the worklist.
- Water Cage work continues
 - Circuit #1 supply line had a small leak on a compression fitting in the water cage.
 - The fitting was replaced
 - This is NOT the major source of the dump water leak
 - Applied the CARGO Sealup
 - Will let the system cure until Monday, March 28th.
 - Will then leak check circuit #1
 - The dump water system remains off and circuit #2 has one valve shut to prevent natural circulation cooling.
 - Plan is to run both circuit #1 and #2 when we resume operations next week.
 - By running flow through both circuits, we cut the velocity in half, overall pressure reduced.
 - The hope is to prolong the lifetime of the sealup patches.
- Will be ready to resume stacking by Tuesday.